





Interstellar Testing Centre Pvt. Ltd.





Test Report

Document QF : 2501
Page 1 of 3

Issued To Modern Water Treatment Service # 1095, Sector-42 B, Chandigarh	Sample Reg. No. : E01-2310190482 Sample Reg. Date : 19-10-2023 Report Date : 23-10-2023 Report No. : ICE-2310230610 NABL ULR No. : TC592623000012231F Customer Ref. No.: Letter Letter Dated : 19.10.2023
Test Report as per IS: BIS Specification IS:10500-2012	With Amendment No.(s): 01 TO 04
PART A : PARTICULARS OF SAMPLE SUBMITTED	
a) Nature of Sample*	Drinking Water
b) Sample Condition	Good
c) Grade / Variety / Type / Class / Size etc.	NA
d) Brand Name	NA
e) Declared Values, if any	NA
f) Code No.	
g) Batch Number*	NA
h) D.O.M*	NA
i) Date of Expiry*	NA
j) Sample Quantity*	750ml
k) Batch Size/Location*	NA
l) Mode of Packing	Packed in bottle
m) Date of Receipt	19-10-2023
n) Date of Start	19-10-2023
o) Date of Completion	23-10-2023
p) Seal (Intact/Not Intact/Unsealed)	NA
q) ICS Signature (Signed/Unsigned)	Unsigned
r) Any Other Information	Sample from Patel Public School, S.D.M. Road, Rajpura


23-10-2023
Deepika Heera
[Authorized Signatory]


Vikrant
23-10-2023
Reviewer


23-10-2023
Prem Kumar
[Authorized Signatory]

*Recd Gate Sankar
31/10/23*

Interstellar Testing Centre Pvt. Ltd.
86, Industrial Area, Phase-I,
Panchkula-134109 (Haryana)
Phone : (01) 0172-2561543, 2565825,
E-mail : customersupport@itclabs.com
Visit us: www.itclabs.com

Disclaimer:

1. The report is only for the sample tested.
2. Total liability of ITC Labs is limited to invoiced amount.
3. The test report shall not be reproduced except in full without the written approval of the laboratory.
4. If samples not consumed during analysis, it will be stored & return to the customer only.
5. Samples not drawn by us unless otherwise stated.
6. Test report in full or parts shall not be used for promotional or public relations purposes.
7. Legal disputes are subjected to Panchkula Jurisdiction only.



Interstellar Testing Centre Pvt. Ltd.



Test Report

Document OF: 2501
Page 2 of 3


Issued To Modern Water Treatment Service # 1095, Sector-42 B, Chandigarh	Sample Reg. No. :E01-2310190482
	Sample Reg. Date :19-10-2023
	Report Date :23-10-2023
	Report No. :ICE-2310230610
	NABL ULR No. :TC592623000012231F
	Customer Ref. No.:Letter Letter Dated :19.10.2023


s) Test Request Submitted By	Modern Water Treatment Service-Chandigarh (Chandigarh)
t) Manufactured By*	Modern Water Treatment Service
u) Supplied By*	Modern Water Treatment Service

PART B : SUPPLEMENTARY INFORMATIONS

a. Reference to sampling procedure, whenever applicable	: N/A
b. Supporting documents for the measurement taken and results derived like graphs, tables, sketches and / or photographs as appropriate to test reports, if any	: N/A
c. Deviation from the test methods as prescribed in relevant ISS/WORK Instruments, if any	: N/A

Description						
Description		Clear colourless liquid				
S.No.	Parameters	Instrument	Method	Acceptable Limit	Permissible Limit	Result
Discipline : Chemical						
Group : Water						
1. Organoleptic & Physical Parameter						
a.	Total Dissolved Solids.(mg/L.)	Gravimetric	IS: 3025 (P-16)-1984 (RA 2017)	500 Max.	2000 Max.	140
Discipline : Biological						
Group : Water						
1. Microbiological Tests						
a.	E. Coli	Microbiological	IS 15185: 2016	Shall not be detectable in any 100 ml sample	No Relaxation	Absent/100 ml


23-10-2023
Deepika Heera
[Authorized Signatory]


Vikrant
23-10-2023
Reviewer


23-10-2023
Prem Kumar
[Authorized Signatory]

Interstellar Testing Centre Pvt. Ltd.

86, Industrial Area, Phase-I,
Panchkula-134109 (Haryana)
Phone : (O) 0172-2561543, 2565825.
E-mail : customersupport@itclabs.com
Visit us: www.itclabs.com

Disclaimer:

1. The report is only for the sample tested.
2. Total liability of ITC Labs is limited to invoiced amount.
3. The test report shall not be reproduced except in full without the written approval of the Laboratory.
4. If samples not conserved during analysis, it will be stored & retain as per company policy.
5. Samples not drawn by us unless otherwise stated.
6. Test report in full or parts shall not be used for promotional or publicity purposes.
7. ITC Labs is not responsible for any loss or damage to the samples.



Test Report

Document Of : 2501
Page 3 of 3


Issued To Modern Water Treatment Service # 1095, Sector-42 B, Chandigarh		Sample Reg. No. :E01-2310190482 Sample Reg. Date :19-10-2023 Report Date :23-10-2023 Report No. :ICE-2310230610 NABL ULR No. :TC592623000012231F Customer Ref. No. :Leiter Letter Dated :19.10.2023				
b.	Total Coliform	Microbiological	IS 15185: 2016	Shall not be detectable in any 100 ml sample	No Relaxation	Absent/100 ml


* represents Customer Defined Fields


NOTE : NA- Not Applicable, BLQ- Below limit of Quantification, LOQ- Limit of Quantification, Sample Submitted by Customer.

REMARKS : The above referred sample of Drinking Water conforms to BIS Specification IS:10500-2012 with upto date amtds with respect to the above tests.

*****End Of Report*****


23-10-2023
Deepika Heera
[Authorized Signatory]


Vikrant
23-10-2023
Reviewer


23-10-2023
Prem Kumar
[Authorized Signatory]

Disclaimer:

1. The report is only for the sample tested.
2. Total liability of ITC Labs is limited to invoiced amount.
3. The test report shall not be reproduced except in full without the written approval of the laboratory.
4. If samples not conserved during analysis, it will be stored & return as per company policy.
5. Samples not drawn by us unless otherwise stated.
6. Test report in full or parts shall not be used for promotional or publicity purposes.
7. Legal disputes are subjected to Panchkula Jurisdiction only.